

Brecon Cathedral, Cathedral Close, Brecon.					Survey Type >			Management		Initial Survey Date(s) >							19/10/2015					
5575AS196																	Management Action					
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
E				5575AS19 6-008	Basement floor - Crypt	To bellows (organ part)	No access	NA (no access)	No access (Presumption)	NA	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	19/10/15		No access into bellows, however may contain asbestos insulation - Do not remove or access bellows prior to refurbishment survey	
E				5575AS19 6-013	First floor - Organ room	Bellows internals and organ internals	No access	NA (no access)	No access (Presumption)	NA	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	19/10/15		Unable to remove bellows panel as organ requires specialist access	
E				5575AS19 6-014	Ground floor - Vestry	Electrical internals	No access	NA (no access)	No access (Presumption)	NA	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	19/10/15		Live electrics - MEM type fuse boxes can contain asbestos. Isolation required for further inspection	
F	5575 AS19 6-002			5575AS19 6-003	Ground floor - Bishop's vestry and Dean's vestry	Closer boards to fireplace	Lining board	Insulating board	No asbestos suspected (extrapolation)	5SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			
F	5575 AS19 6-002			5575AS19 6-010	Cathedral tower - Bell ringing room	Door lining to roof space door	Lining board	Insulating board	No asbestos suspected (extrapolation)	1LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			
G			NGAR6 203-1	5575AS19 6-002	First floor - Archive room	Closer boards to fireplace	Lining board	Insulating board	Negative asbestos sample	2SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			
G			NGAR6 203-2	5575AS19 6-006	Ground floor - Boiler room 2	Ceiling	Lining board	Insulating board	Negative asbestos sample	2SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			
G			NGAR6 203-3	5575AS19 6-009	Basement floor - Crypt	To bellows	Gasket	Textiles - Gaskets & washers	Negative asbestos sample	Small Quants	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			
G			NGAR6 203-4	5575AS19 6-012	First floor - Organ room	Gator between trunking and bellows	Cloth	Textiles - cloth	Negative asbestos sample	Small Quants	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			
H				5575AS19 6-001	First floor - WC	Floor covering	Vinyl sheet	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			
H				5575AS19 6-004	Ground floor - Kitchen and male, female and disabled toilets	Floor coverings	Vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	36SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15			

Brecon Cathedral, Cathedral Close, Brecon.				Survey Type >			Management		Initial Survey Date(s) >								19/10/2015							
5575AS196																	Management Action							
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation			Last date ACM inspected	Last date ACM modified	Note	Licensed work?
H				5575AS196-005	Ground floor - Boiler room	To boiler internals 2 no. boilers	Gasket	Textiles - Gaskets & washers	Discounted material (not sampled)	Small Quants	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15		Fonderie SIME RMG 100			
H				5575AS196-007	Ground floor - Boiler room 2	To pipework	Thermal insulation	Thermal insulation	Discounted material (not sampled)	20LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15		Canvas and band			
H				5575AS196-011	Cathedral tower - walkway (over looking nave)	Panel to wall	Lining board	Insulating board	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15		New supalux board			
H				5575AS196-015	Roofs	Roof coverings	Natural roof slate	Cement - Fully comp flat sheet, tiles, slates & boards	Discounted material (not sampled)	800SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/10/15					