

KOVIA[®]

Asbestos Consultancy

+44(0)1752 875 642

kovia.co.uk

info@kovia.co.uk

Sampling Survey

10 Constantine Court
10 Constantine Street
Tonypany
Mid Glamorgan
CF40 1QL
UPRN: 006368



Kovia Ltd
1 Davy Road
Derriford
Plymouth
PL6 8BX





Plan Key:



Positive or Strongly Presumed Asbestos in area / room



No Access within or to area / room

Client: Wales & West Housing
Site: 10 Constantine Court Building: Flat 10, Block 1-35
Floor: Ground Floor
UPRN No: 006368





Our Ref: J186153 Fl: 2
Your Ref:
Date: 28/02/2020

ENVIROCHEM
Analytical Laboratories Ltd.
12 The Gardens
Broadcut, Fareham
Hampshire
PO16 8SS



Tel: (01329) 287777
Fax: (01329) 287755
www.envirochem.co.uk
office@envirochem.co.uk

Asbestos Fibre Identification Report

Client: Kovia Asbestos Management Consultancy
1 Davy Road, Derriford, Plymouth, PL6 8BX

Site Address: 10 Constantine Court, 10 Constantine Street, Tonypanydy, Mid Glamorgan, CF40 1QL

Sampled By: Kovia Asbestos Management Consultancy

Date sampled/received: 28th February 2020

Date analysed: 28th February 2020

Analyst/s: Ewelina Kowalczyk Pariyar

Analysis Location: 12 The Gardens, Broadcut, Fareham, Hampshire, PO16 8SS

ANALYTICAL PROCEDURE

Fibre identification was carried out in accordance with the documented 'in-house' method (2.01) based on the HSE Guidance Note HSG 248. These employed stereo microscopy, polarized microscopy and dispersion staining techniques.

RESULTS

Sample No.	Sample Ref.	Location	Asbestos Detected	Asbestos Type
AI008732	BS605438	Ground Floor, Lounge, Textured coating	No	
AI008733	BS605439	Ground Floor, Bathroom, Textured coating	No	

NOTES:

1. Sample(s) were examined for the presence of 6 types of asbestos fibres: crocidolite (blue), amosite (brown), chrysotile (white), anthophyllite, actinolite and tremolite.
2. The results shown in this test report specifically refer to the sample(s) tested as received unless otherwise stated and samples collected by the client are evaluated using information provided by the client. For samples collected by the client the date of receipt is deemed to be the same as the date sampled.
3. Envirochem is a UKAS accredited laboratory for sampling and identification of asbestos containing materials.
4. Comments, observations and opinions are outside the scope of UKAS accreditation.
5. The analytical method in the HSG248 does not quantify the amount of asbestos present, therefore UKAS accreditation does not permit quantification.
6. If, during fibre identification, only 1 or 2 fibres are seen and identified as asbestos, then the term 'trace asbestos identified' is used.
7. This report shall not be reproduced except in full, without written approval of Envirochem.

SIGNATURE: *Kowalczyk*

Authorised signatory

PRINT NAME: Ewelina Kowalczyk Pariyar

Reg. No. 2378228 England. Registered Office: Envirochem, 12 The Gardens, Broadcut, Fareham, Hampshire, PO16 8SS.