

| 9 Bethlehem View, Chapel Road, Pontyclun. | | | | Survey Type > | | | | Management | | | | Initial Survey Date(s) > | | | | 19/06/2014 | | | | | | | | |
|---|----------------------------|----------------------|-------------|----------------|--|------------------------|-----------------------|--|-----------------------------------|--------------------------|------------------|--------------------------|----------------------|---|--------------------------------|---|-------------------------|---|--|-------------------------|------------------------|------|--|--|
| 2220AS1067 | | | | | | | | | | | | Risk ratings | | | | Management Action | | | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" - Score breakdown available on request | Total Risk Rating "A+B" |  | | Last date ACM inspected | Last date ACM modified | Note | Licensed work? | |
| E | | | | 2220AS1067-011 | GF - Kitchen and under stairs cupboard | Under current flooring | NA | No access (Presumption) | No access (Presumption) | 160 | NA | NA | NA | NA | NA | NA | NA | Re-evaluate if access obtained | | 27/07/23 | | | | |
| G | | | NGAR03351-1 | 2220AS1067-003 | GF - Hall and lounge | Under current flooring | Beige vinyl tile | PVC vinyl floor tiles & unbacked PVC flooring | Negative asbestos sample | 24SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 06/01/17 | | | House contents made it hard to get under carpet or sheet vinyl flooring. Tile sample taken | |
| G | | | NGAR03351-1 | 2220AS1067-004 | GF - Living room | Ceiling | 'Artex' - 'Fan' | Textured coatings & joint compound | Negative asbestos sample | 15SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| G | | | NGAR03351-2 | 2220AS1067-005 | GF - Under stairs cupboard, under side of stairs and | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 6SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| G | | | NGAR03351-3 | 2220AS1067-007 | FF - All areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 40SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| G | | | NGAR03351-4 | 2220AS1067-010 | External - Roof and porch | Under cloak | Lining board | Cement - Fully comp flat sheet, tiles, slates & boards | Negative asbestos sample | 14LM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| H | | | | 2220AS1067-001 | GF - Kitchen | Under side sink top | Bitumen pad | Bitumen coatings on metal | Discounted material (not sampled) | 1No | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| H | | | | 2220AS1067-002 | GF - Kitchen and under stairs cupboard | Floors | Beige sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 16SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| H | | | | 2220AS1067-006 | FF - Bathroom | Floor | Blue/grey sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| H | | | | 2220AS1067-008 | Roof space | Under roof covering | Sarking felt | Bitumen roofing felts | Discounted material (not sampled) | 45SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | | |
| H | | | | 2220AS1067-009 | External | Low level brick work | Damp proof course | Bitumen damp proof courses | Discounted material (not sampled) | 40SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | | 19/06/14 | | | Plastic | |