

11 Summerfield Court, Trealaw, Tonypanydy.				Survey Type >		Update Asbestos Survey		Initial Survey Date(s) >							24/06/2014								
2220AS1073								Risk ratings							Management Action								
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"			Last date ACM inspected	Last date ACM modified	Note	Licensed work?
E				2220AS1073-002	GF - All areas except for under stairs cupboard	Under current floors	N/A	No access (Presumption)	No access (Presumption)	39SM	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	27/10/23				
G			NGAR03391-1	2220AS1073-003	GF - Living room	Ceiling	'Artex' - 'Fan'	Textured coatings & joint compound	Negative asbestos sample	15SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14				
G			NGAR03391-2	2220AS1073-004	GF - All areas except for living room	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	25SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14				
G			NGAR03391-3	2220AS1073-006	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14				
G			NGAR03391-4	2220AS1073-009	External - Porch and main roof	Undercloak	Lining board	Insulating board	Negative asbestos sample	13LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14				
H				2220AS1073-001	GF - Kitchen and WC	Floors	Grey sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	17SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14				
H				2220AS1073-005	FF - Bathroom	Floor	Black sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14				
H				2220AS1073-007	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	45SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14				
H				2220AS1073-008	External	Low level brick work	Damp proof courses	Bitumen damp proof courses	Discounted material (not sampled)	35LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/06/14			Plastic	