

13 Gelli Fedi Rise, Brynna, Pontyclun.					Survey Type >		Management		Initial Survey Date(s) >							09/07/2014							
2220AS1105									Risk ratings							Management Action							
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation		Last date ACM inspected	Last date ACM modified	Note	Licensed work?
E				2220AS1105-007	Ground floor - all areas except under stairs cupboard	Under current floors	N/A	No access (Presumption)	No access (Presumption)	40SM	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	16/10/23				
E				2220AS1105-009	External - Roof and porch	Undercloak	N/A	No access (Presumption)	No access (Presumption)	NA	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	16/10/23			Covered by uPVC	
G			NGAR03465-1	2220AS1105-003	Ground floor - all areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	42SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/14				
G			NGAR03465-2	2220AS1105-005	First floor - all areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/14				
H				2220AS1105-001	Ground floor - kitchen	Under sink	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/14				
H				2220AS1105-002	Ground floor - kitchen	Floor	Grey sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	15SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/14				
H				2220AS1105-004	First floor - bathroom	Floor	Black sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/14				
H				2220AS1105-006	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	45SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/14				
H				2220AS1105-008	External	Low level brick work	Damp proof courses	Bitumen damp proof courses	Discounted material	30LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/14			Plastic	