

Kitchen - 8 School Villas, Stanleytown, Ferndale.					Survey Type >		Refurbishment		Initial Survey Date(s) >							18/07/2016						
2220AS1125A					Register Type >		Final		Risk ratings							Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			NGAR03560-2	2220AS1125A-005	Ground floor - Kitchen	Ceiling	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	15SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/07/16		Previously sampled as negative please refer to management report	
G			NGAR7934-1	2220AS1125A-006	Ground floor - Kitchen	Underside of worktops	Paper lining	Paper inc lining to 'strawboard'	Negative asbestos sample	3SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/07/16			
H				2220AS1125A-001	Ground floor - Kitchen	Floor	Grey vinyl sheet	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	15SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/07/16			
H				2220AS1125A-002	Ground floor - Kitchen	Underside of sink	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/07/16			
H				2220AS1125A-003	Ground floor - Kitchen	Within wall mounted boiler	Gaskets	Textiles - Gaskets & washers	Discounted material (not sampled)	Small Quants	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/07/16		Ideal classic boiler	
H				2220AS1125A-004	Ground floor - Kitchen	Walls above worktops	Ceramic tiles	Ceramic	Discounted material (not sampled)	3SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/07/16			

* risk assessment required prior to work.

Where 'Carry Out Repairs', 'Seal', 'Encapsulate' or 'Enclose' is recommended, it is implicit that the ACM is also classified as 'Record, Manage and Monitor'.