

66 South Street, Ynysir, Porth.					Survey Type >		Management		Initial Survey Date(s) >							01/08/2014									
2220AS1136																Management Action									
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation				Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			NGAR03605-1	2220AS1136-002	GF - Under stairs cupboard, living room and hall	Ceiling in under stairs cupboard and high level joist in living room and hall	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	5SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						
G			NGAR03605-2	2220AS1136-003	GF - Hall and FF - Bedroom 3	Ceilings	'Artex' - 'Circle/Stipple'	Textured coatings & joint compound	Negative asbestos sample	13SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						
G			NGAR03605-3	2220AS1136-004	FF - Bedroom 1	Ceiling	'Artex' - 'Flower in a basket'	Textured coatings & joint compound	Negative asbestos sample	9SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						
G			NGAR03605-4	2220AS1136-005	FF - Landing	Ceiling	'Artex' - 'Fan/Shell'	Textured coatings & joint compound	Negative asbestos sample	5SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						
G			NGAR03605-5	2220AS1136-006	FF - Bathroom and bedroom 2	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	15SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						
H				2220AS1136-001	GF - Kitchen	Under sink	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						
H				2220AS1136-007	FF - Bathroom	Floor	Grey sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						
H				2220AS1136-008	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	48SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	01/08/14						