

| 5 Stanley Court, Cwmparc, Treorchy. | | | | Survey Type > | | Update Asbestos Survey | | Initial Survey Date(s) > | | | | | | | 15/08/2014 | | | | | | | |
|-------------------------------------|----------------------------|----------------------|-------------|-----------------|--|-------------------------------|----------------------------|---|-----------------------------------|--------------------------|------------------|-----------|----------------------|--|--------------------------------|---|-------------------------|--|-------------------------|------------------------|--|----------------|
| 2220AS1155 | | | | Register Type > | | Final | | Risk ratings | | | | | | | Management Action | | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" - Score breakdown available on request | Total Risk Rating "A+B" |  Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| A | | | NGAR03673-2 | 2220AS1155-005 | External - front and rear porch | Gable end undercloak to verge | Lining board | Insulating board | Positive asbestos sample | 4LM | 0 | 0 | 2 | 1 | 5 | 0 | 5 | Record, manage & monitor | 16/11/23 | | | Yes |
| G | | | NGAR03673-1 | 2220AS1155-004 | Ground floor - all areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 48SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 15/08/14 | | | |
| G | | | PHH24559-1 | 2220AS1155-006 | Ground floor - hall, living room, kitchen and bathroom | Under laminate floors | Tiles and adhesive | PVC vinyl floor tiles & unbacked PVC flooring | Negative asbestos sample | 29SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 03/11/21 | 03/11/21 | Surveyor accessed beneath flooring, and found tiles. | |
| H | | | | 2220AS1155-001 | Ground floor - kitchen | Under sink | Bitumen pad | Bitumen coatings on metal | Discounted material (not sampled) | 1No | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 15/08/14 | | | |
| H | | | | 2220AS1155-002 | Ground floor - kitchen | Floor | Blue sheet vinyl flooring | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 5SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 15/08/14 | | | |
| H | | | | 2220AS1155-003 | Ground floor - bathroom | Floor | Green sheet vinyl flooring | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 15/08/14 | | | |