

13 Treharne Street, Pentre.					Survey Type >		Management		Initial Survey Date(s) >						02/07/2010							
2220AS116															Management Action							
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	* Accessibility	* Damage	* Surface treatment	Risk ratings				Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"						
G		08TRE01300	00005/809-1	2220AS116-001	GF - Hall	Ceilings	'Artex' - 'Circle'	Textured coatings & joint compound	Negative asbestos sample	1SM	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				
G		08TRE01300	00005/809-2	2220AS116-002	GF - Lounge	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				
G		08TRE01300	00005/809-3	2220AS116-003	GF - Kitchen and lounge	Ceilings	'Artex' - 'Fan'	Textured coatings & joint compound	Negative asbestos sample	28SM	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				
G		08TRE01300	00005/809-4	2220AS116-005	FF - Bathroom and bedroom 3	Ceiling	'Artex' - 'Shell'	Textured coatings & joint compound	Negative asbestos sample	18SM	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				
G		08TRE01300	00005/809-5	2220AS116-006	FF - Bedroom 2	Ceiling	'Artex' - 'Circle'	Textured coatings & joint compound	Negative asbestos sample	12SM	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				
G		08TRE01300	00005/809-6	2220AS116-007	FF - Landing and bedroom 1	Ceilings	'Artex' - 'Fan'	Textured coatings & joint compound	Negative asbestos sample	16SM	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				
H		08TRE01300		2220AS116-004	GF - Kitchen	Underside sink top	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				
H		08TRE01300		2220AS116-008	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	No action not an ACM	02/07/10				