21 Graig Wen, Maerdy, Ferndale.				Survey Type >		Update Asbestos Survey													Initial Survey Date(s) >			24/10/2014	
2220AS1207															Risk ratings				Management Action				
Report Section	Extrapolated from Site Ref	UPRN (If applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
A			NGAR4 008-2	2220AS12 07-005	External - Porch	Under cloak	Lining board	Cement - Fully comp flat sheet, tiles, slates & boards	Positive asbestos sample	4LM	0	0	1	1	3	0	3	Record, manage & monitor	11/01/24			No*
G			NGAR4 008-1	2220AS12 07-004	Ground floor - Hall and First floor - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	56SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/10/14			
H				2220AS12 07-001	First floor - Bathroom	Under sink	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/10/14			
H				2220AS12 07-002	First floor - Kitchen	Floor	Black sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	7SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/10/14			
H				2220AS12 07-003	First floor - Bathroom	Floor	Grey sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/10/14			
H				2220AS12 07-006	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	60SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/10/14			