

Bathroom - 14 Clos Ynysygrug, Trealaw Road, Trealaw, Tonypandy.					Survey Type >		Refurbishment		Initial Survey Date(s) >							19/01/2017						
2220AS1287B					Register Type >		Final		Risk ratings							Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			NGAR04201-2	2220AS1287B-004	Bathroom	Ceiling above polystyrene tiles	'Artex' -'Stipple'	Textured coatings & joint compound	Negative asbestos sample	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/01/17		Previously sampled as negative, please refer to 2220AS1287-008	
G			PHH1054-1	2220AS1287B-006	Bathroom	Bath panel	Lining board	Insulating board	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/01/17			
H				2220AS1287B-001	Bathroom	Floor	Grey vinyl tiles	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/01/17		Self adhesive tiles	
H				2220AS1287B-002	Bathroom	Under current flooring	Beige vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/01/17			
H				2220AS1287B-003	Bathroom	Ceiling	Polystyrene ceiling tiles	Insulation board as ceiling tiles	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/01/17			
H				2220AS1287B-005	Bathroom	Walls	Ceramic tiles	Other	Discounted material (not sampled)	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	19/01/17		Ceramic	

* risk assessment required prior to work.

Where 'Carry Out Repairs', 'Seal', 'Encapsulate' or 'Enclose' is recommended, it is implicit that the ACM is also classified as 'Record, Manage and Monitor'.