

| 97B Dunraven Street, Tonypanydy. | | | | | Survey Type > | Refurbishment | Initial Survey Date(s) > | | | | | 30/07/2019 | | | | | | | | | | | |
|----------------------------------|----------------------------|----------------------|-------------|------------------|-------------------|--|--------------------------|---|-----------------------------------|--------------------------|------------------|------------|----------------------|--|--------------------------------|---|-------------------------|--|-------------------------|------------------------|------|--|--|
| 2220AS1337A | | | | | Register Type > | Final | | Risk ratings | | | | | Management Action | | | | | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" - Score breakdown available on request | Total Risk Rating "A+B" |  Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? | |
| G | | | PHH12 296-1 | 2220AS13 37A-003 | Office 2 | Lining to vertical boxing - Behind timber lining | Board | Insulating board | Negative asbestos sample | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |
| G | | | PHH12 296-2 | 2220AS13 37A-004 | Kitchen | Lining to boxing - Behind timber lining | Board | Insulating board | Negative asbestos sample | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |
| G | | | NGAR7 340-1 | 2220AS13 37A-005 | Kitchen | Under sink | Bitumen pad | Bitumen coatings on metal | Negative asbestos sample | 1No | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | Previously sampled as negative, please refer to 2220AS1337-003 | |
| H | | | | 2220AS13 37A-001 | All areas | Suspended ceilings | Tiles | Insulation board as ceiling tiles | Discounted material (not sampled) | 100SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |
| H | | | | 2220AS13 37A-002 | Electric cupboard | Wall mounted | Cable wrap | Reinforced plastic and resin composites | Discounted material (not sampled) | 1LM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |
| H | | | | 2220AS13 37A-006 | Kitchen | Wall mounted | Fire blanket | Textiles - cloth | Discounted material (not sampled) | 1No | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |
| H | | | | 2220AS13 37A-007 | Kitchen and WC | Floors | Grey vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 9SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |
| H | | | | 2220AS13 37A-008 | Internal | Door lining x2 | Fire strips | AIB cores & linings composite products | Discounted material (not sampled) | 8LM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |
| H | | | | 2220AS13 37A-009 | Kitchen | Wall mounted dimplex storage heater | Within heater | AIB cores & linings composite products | Discounted material (not sampled) | 1no | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 30/07/19 | | | | |