

| 2 Ashfield Close, Cumber Road, Porth. | | | | Survey Type > | | Management | | Initial Survey Date(s) > | | | | | | | 04/10/2010 | | | | | | | | | |
|---------------------------------------|----------------------------|----------------------|---------------|----------------|-------------------------|------------|---------------------------|---|-----------------------------------|--------------------------|-----------------|----------|---------------------|--------------------------------|--------------------------------|-------------------------|---|----------|--|--|-------------------------|------------------------|------|----------------|
| 2220AS143 | | | | | | | | Risk ratings | | | | | | | Management Action | | | | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | * Accessibility | * Damage | * Surface treatment | Total Material Risk rating "A" | Total Priority Risk rating "B" | Total Risk Rating "A+B" |  Recommendation | | | | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| G | | | 00005/B1107-1 | 2220AS14-3-001 | Lounge | Ceiling | 'Artex' - 'Fan' | Textured coatings & joint compound | Negative asbestos sample | 11SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 04/10/10 | | | | | | |
| G | | | 00005/B1107-2 | 2220AS14-3-002 | All areas except lounge | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 26SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 04/10/10 | | | | | | |
| H | | | | 2220AS14-3-003 | Kitchen | Floor | Grey vinyl sheet flooring | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 5SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 04/10/10 | | | | | | |