

8 Tyle Fforest, Treherbert, Treorchy.				Survey Type >			Management			Initial Survey Date(s) >						03/02/2023						
2220AS1447				Register Type >			Final			Risk ratings						Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			J03872 5-1	2220AS14 47-001	GF - Kitchen cupboard	Floor	Beige tiles and adhesive	PVC vinyl flooring and adhesive	Negative asbestos sample	2SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
G			J03872 5-2	2220AS14 47-002	GF - All areas except lounge	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	32SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
G			J03872 5-3	2220AS14 47-003	GF - Lounge	Ceiling	'Artex' - 'Fan'	Textured coatings & joint compound	Negative asbestos sample	20SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
G			J03872 5-4	2220AS14 47-004	GF - Kitchen	Under sink	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	Small Quants	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
G			J03872 5-5	2220AS14 47-007	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	48SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
G			J03872 5-6	2220AS14 47-010	Porch	Gable end - undercloak to verges	Lining board	Insulating board	Negative asbestos sample	1LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
H				2220AS14 47-005	GF - Toilet	Behind toilet	Waste pipe	Reinforced plastic and resin composites	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
H				2220AS14 47-006	GF - Toilet	Floor	Beige sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
H				2220AS14 47-008	FF - Bathroom	Floor	Beige sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	5SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			
H				2220AS14 47-009	Roof spce	Under roof	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/02/23			