

20 Constantine Court, Constantine Street, Williamstown, Tonypanydy. 2220AS1550				Survey Type >		Management		Initial Survey Date(s) >							19/04/2023						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Risk ratings			Management Action			
															Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation		Last date ACM inspected	Last date ACM modified
G			E-35722/1-1	2220AS1550-006	Bathroom	Next to sink	Boxing	Insulating board	Negative asbestos sample	3SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			
G			E-35722/1-2	2220AS1550-007	All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	340	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			
G			E-35722/1-3	2220AS1550-008	Kitchen	Next to sink	Vertical boxing	Insulating board	Negative asbestos sample	2LM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			
H				2220AS1550-001	Kitchen	Floor	Brown sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	5SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			
H				2220AS1550-002	Kitchen	Under sink	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	Small Quants	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			
H				2220AS1550-003	Kitchen	Around worktop	Mastic	Bitumen mastic, caulking & putty	Discounted material (not sampled)	Small Quants	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			
H				2220AS1550-004	Bathroom	Floor	White sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			
H				2220AS1550-005	Bathroom	Behind toilet	Waste pipe	Reinforced plastic and resin composites	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	No action not an ACM	19/04/23			