

Kitchen - 43 Dumfries Street, Treherbert, Treorchy.					Survey Type >		Refurbishment		Initial Survey Date(s) >							17/07/2017						
2220AS15A					Register Type >		Final		Risk ratings							Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			91558/B455-3	2220AS15 A-003	Kitchen	Ceiling	'Artex' - 'Streak'	Textured coatings & joint compound	Negative asbestos sample	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	17/07/17		Previously sampled as negative, please refer to 2220AS15-005	
G			91558/B455-2	2220AS15 A-004	Kitchen	Under current flooring and screed	Cream vinyl tiles and adhesive	PVC vinyl floor tiles & unbacked PVC flooring	Negative asbestos sample	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	17/07/17		Previously sampled as negative, please refer to 2220AS15-002	
G			PHH26 01-1	2220AS15 A-006	Kitchen	Underside of work tops	Paper lining	Paper inc lining to 'strawboard'	Negative asbestos sample	2SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	17/07/17			
H				2220AS15 A-001	Kitchen	Under side of sink top and drainer	Bitumen pads	Bitumen coatings on metal	Discounted material (not sampled)	4No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	17/07/17			
H				2220AS15 A-002	Kitchen	Floor	Grey vinyl flooring sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	17/07/17			
H				2220AS15 A-005	Kitchen	Walls above work tops	Ceramic tiles	Other	Discounted material (not sampled)	3SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	17/07/17			