

17 Eileen Street, Tynewydd, Treorchy.					Survey Type >		Type 2			Initial Survey Date(s) >					16/12/2009							
Report Section	Extrapolated from Site Ref	UPRN	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	Accessibility	Damage	Surface treatment	Risk ratings			Management Action					
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	 Recommendation				Last date ACM inspected	Last date ACM modified
G		03EIL01700	91558/B479-1	2220AS20-001	GF - Bathroom, kitchen, halls 1, 2 and under stairs cupboard	Ceilings	'Artex' - 'Random'	Textured coatings & joint compound	Negative asbestos sample	24SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				
G		03EIL01700	91558/B479-2	2220AS20-002	GF - Kitchen	Underside sink top	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				
G		03EIL01700	91558/B479-3	2220AS20-003	GF - Under stairs cupboard	Floor	Mauve vinyl tiles	PVC vinyl floor tiles & unbacked PVC flooring	Negative asbestos sample	2SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				
G		03EIL01700	91558/B479-4	2220AS20-004	External - Roof	Roof covering	Slate	Cement - Fully comp flat sheet, tiles, slates & boards	Negative asbestos sample	50SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				
G		03EIL01700	91558/B479-5	2220AS20-007	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	32SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				
G		03EIL01700	91558/B479-6	2220AS20-008	Roof space	Under roof coverings	Sarking felt	Bitumen roofing felts	Negative asbestos sample	50SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				
H		03EIL01700		2220AS20-005	GF - Kitchen & bathroom	Floors	Tile effect vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	12SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				
H		03EIL01700		2220AS20-006	GF - Hall 2	Floor	Self stick vinyl tiles	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	3SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/12/09				