

| 16 Glenrhondda Court, Dunraven Street, Treherbet. | | | | | Survey Type > | | | Management | | Initial Survey Date(s) > | | | | | | 17/01/2011 | | | | | | |
|---|----------------------------|----------------------|------------|----------------|-----------------------|---------------------------|----------------------------|--|-----------------------------------|--------------------------|------------------|-----------|----------------------|--------------------------------|--------------------------------|-------------------------|---|----------------|-------------------------|------------------------|------|----------------|
| 2220AS249 | | | | | | | | | | | | | | | | Management Action | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Risk ratings | | |  | Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| | | | | | | | | | | | | | | Total Material Risk rating "A" | Total Priority Risk rating "B" | Total Risk Rating "A+B" | | | | | | |
| G | | | NGA30 38-1 | 2220AS24 9-003 | All first floor rooms | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 46SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 17/01/11 | | | | |
| G | | | NGA30 38-2 | 2220AS24 9-005 | Roof space | Roof coverings | Slates | Cement - Fully comp flat sheet, tiles, slates & boards | Negative asbestos sample | 60SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 17/01/11 | | | | |
| H | | | | 2220AS24 9-001 | Kitchen | Under sink top | Bitumen pads | Bitumen coatings on metal | Discounted material (not sampled) | 1No | NA | NA | NA | NA | NA | NA | No action not an ACM | 17/01/11 | | | | |
| H | | | | 2220AS24 9-002 | Bathroom and kitchen | Floors | Beige vinyl sheet flooring | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 12SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 17/01/11 | | | | |
| H | | | | 2220AS24 9-004 | Roof space | Under side roof coverings | Sarking felt | Bitumen roofing felts | Discounted material (not sampled) | 60SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 17/01/11 | | | | |