

| Kitchen - 62 Scott Street, Tynewydd, Treorchy. | | | | | Survey Type > | | Refurbishment | | Initial Survey Date(s) > | | | | | | | 14/02/2020 | | | | | | | |
|--|----------------------------|----------------------|-------------|----------------|-----------------|-----------------------|--------------------------|------------------------------------|-----------------------------------|--------------------------|------------------|-----------|----------------------|--|--------------------------------|---|-------------------------|---|----------|-------------------------|------------------------|------|----------------|
| 2220AS24A | | | | | Register Type > | | Final | | Risk ratings | | | | | | | Management Action | | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" - Score breakdown available on request | Total Risk Rating "A+B" |  Recommendation | | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| G | | | | 2220AS24 A-001 | Kitchen | Ceiling | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 9SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 14/02/20 | | | | |
| G | | | PHH15 231-1 | 2220AS24 A-003 | Kitchen | Beneath ceramic tiles | Beige tiles and adhesive | PVC vinyl flooring and adhesive | Negative asbestos sample | 9SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 14/02/20 | | | | |
| H | | | | 2220AS24 A-002 | Kitchen | Beneath basin | Bitumen pad | Bitumen coatings on metal | Discounted material (not sampled) | 1No | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 14/02/20 | | | | |

* risk assessment required prior to work.

Where 'Carry Out Repairs', 'Seal', 'Encapsulate' or 'Enclose' is recommended, it is implicit that the ACM is also classified as 'Record, Manage and Monitor'.