

153 Parc Road, Cwmparc, Treorchy.					Survey Type >			Management		Initial Survey Date(s) >						18/02/2011					
2220AS290																Management Action					
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Risk ratings				Last date ACM inspected	Last date ACM modified	Note	Licensed work?
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"					
G			NGA34 70-1	2220AS29 0-002	GF - Lounge	Ceiling	'Artex' - 'Fan'	Textured coatings & joint compound	Negative asbestos sample	14SM	NA	NA	NA	NA	NA	NA	No action not an ACM	18/02/11			
G			NGA34 70-2	2220AS29 0-003	GF - Kitchen	Ceiling	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	14SM	NA	NA	NA	NA	NA	NA	No action not an ACM	18/02/11			
G			NGA34 70-3	2220AS29 0-005	GF - Kitchen	Underside sink top	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	No action not an ACM	18/02/11			
G			NGA34 70-4	2220AS29 0-006	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	28SM	NA	NA	NA	NA	NA	NA	No action not an ACM	18/02/11			
H				2220AS29 0-004	GF - Kitchen	Floor	Blue sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	12SM	NA	NA	NA	NA	NA	NA	No action not an ACM	18/02/11			
H				2220AS29 0-007	FF - Bathroom	Floor	Lemon sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	No action not an ACM	18/02/11			
H				2220AS29 0-008	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	40SM	NA	NA	NA	NA	NA	NA	No action not an ACM	18/02/11			
I				2220AS29 0-001	GF - Lounge	Within back boiler	Gaskets	Textiles - Gaskets & washers	Removed	Small Quants	NA	NA	NA	NA	NA	NA	No action not an ACM	14/07/15			