

| 17 Fredrick Street, Ferndale. | | | | Survey Type > | | Management | | Initial Survey Date(s) > | | | | | | 08/03/2011 | | | | | | | | |
|-------------------------------|----------------------------|----------------------|------------|----------------|----------------|---------------------|----------------------------|---|-----------------------------------|--------------------------|------------------|-----------|----------------------|--------------------------------|--------------------------------|-------------------------|---|----------------|-------------------------|------------------------|------------------------------------|----------------|
| 2220AS320 | | | | | | | | | | | | | | Management Action | | | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Risk ratings | | |  | Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| | | | | | | | | | | | | | | Total Material Risk rating "A" | Total Priority Risk rating "B" | Total Risk Rating "A+B" | | | | | | |
| G | | | NGA37 30-1 | 2220AS32 0-001 | GF - All areas | Floors | Beige vinyl floor tile | PVC vinyl floor tiles & unbacked PVC flooring | Negative asbestos sample | 32SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 08/03/11 | | | | |
| G | | | NGA37 30-2 | 2220AS32 0-002 | GF - All areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 32SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 08/03/11 | | | Tiles under all existing coverings | |
| G | | | NGA37 30-3 | 2220AS32 0-003 | FF - All areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 32SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 08/03/11 | | | | |
| H | | | | 2220AS32 0-004 | FF - Bathroom | Floors | Beige vinyl sheet flooring | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 4SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 08/03/11 | | | | |
| H | | | | 2220AS32 0-005 | Roof space | Under roof covering | Sarking felt | Bitumen roofing felts | Discounted material (not sampled) | 50SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 08/03/11 | | | | |