

4 Stanley Court, Tallis Street, Cwmparc, Treorchy.				Survey Type >			Management			Initial Survey Date(s) >						16/03/2011					
2220AS357																Management Action					
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Risk ratings			 Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"					
G			NGA38 90-1	2220AS35 7-001	GF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	28SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			
G			NGA38 90-2	2220AS35 7-002	GF - All areas	Floors	Beige vinyl tiles	PVC vinyl floor tiles & unbacked PVC flooring	Negative asbestos sample	28SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11		Visible in kitchen, under all existing floor coverings	
G			NGA38 90-3	2220AS35 7-003	GF - Kitchen	Under side of sink and drainer	Bitumen pads	Bitumen coatings on metal	Negative asbestos sample	2No	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			
G			NGA38 90-4	2220AS35 7-004	FF - Landing, bedrooms 1 and 2	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	20SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			
H				2220AS35 7-005	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			
H				2220AS35 7-006	FF - Bathroom	Floor	Sandy speckled vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			
H				2220AS35 7-007	External - Porch roof	Under cloak to gable end verges	Lining board	Insulating board	Discounted material (not sampled)	3LM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			