

Flat 8 Ty Bethania, Herbert Street, Treorchy.				Survey Type >			Management		Initial Survey Date(s) >						16/03/2011						
2220AS361																					
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Risk ratings			Management Action				
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	 Last date ACM inspected Last date ACM modified Note Licensed work?				
G			NGA38 54-1	2220AS36 1-001	All areas	Ceilings	'Artex' - Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			
G			NGA38 54-2	2220AS36 1-002	Kitchen	Under sink and drainer	Bitumen Pads	Bitumen coatings on metal	Negative asbestos sample	2No	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			
H				2220AS36 1-003	Bathroom	Floor	Beige sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	No action not an ACM	16/03/11			