17 Fforch Close, Cemetery Road, Treorchy.						Survey Type >		Management		Initial Survey Date(s) >								15/03/2011			
2220AS366														Risk ratings			Management Action				
Report Section	Extrapolated from Site Ref	UPRN (If applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			NGA3860-1	2220AS366-004	GF - Lounge	Ceiling	'Artex' - 'Random'	Textured coatings & joint compound	Negative asbestos sample	15SM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
G			NGA3860-2	2220AS366-005	GF - Hall and kitchen	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	18SM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
G			NGA3860-3	2220AS366-006	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
H				2220AS366-001	GF - Kitchen	Under side of sink	Bitumen pads	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
H				2220AS366-002	GF - Kitchen	Floor	Grey sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	12SM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
H				2220AS366-003	GF - Hall	Floor	Brown self stick tiles	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
H				2220AS366-007	FF - Bathroom	Floor	Brown sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
H				2220AS366-008	FF - Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			
H				2220AS366-009	External - Porch Roof	Undercloak to gable end	Lining board	Cement - Fully comp flat sheet, tiles, slates & boards	Discounted material (not sampled)	2LM	NA	NA	NA	NA	NA	NA	No action not an ACM	15/03/11			