

11 Swn Yr Afon, Dorothy Street, Gelli, Pentre.				Survey Type >			Management		Initial Survey Date(s) >							19/03/2011					
2220AS382																					
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Risk ratings			Management Action				
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	 Recommendation				Last date ACM inspected
A			NGA40 08-3	2220AS38 2-007	External - Porch roof	Under cloak to gable end verge	Lining board	Cement - Fully comp flat sheet, tiles, slates & boards	Positive asbestos sample	2LM	0	0	1	3	0	3	Record, manage & monitor	12/01/24			No*
G			NGA40 08-1	2220AS38 2-001	GF - All areas except cupboard 2	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	34SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/03/11			
G			NGA40 08-2	2220AS38 2-002	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	35SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/03/11			
H				2220AS38 2-003	GF - Kitchen	Under side of sink and drainer	Bitumen pads	Bitumen coatings on metal	Discounted material (not sampled)	2No	NA	NA	NA	NA	NA	NA	No action not an ACM	19/03/11			
H				2220AS38 2-004	GF - Kitchen - FF - Bathroom	Floors	Beige speckled vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	14SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/03/11			
H				2220AS38 2-005	GF - Cupboard 2	Ceiling	Lining board	Insulating board	Discounted material (not sampled)	1SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/03/11			
H				2220AS38 2-006	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	42SM	NA	NA	NA	NA	NA	NA	No action not an ACM	19/03/11			

\* risk assessment required prior to work.

Where 'Carry Out Repairs', 'Seal', 'Encapsulate' or 'Enclose' is recommended, it is implicit that the ACM is also classified as 'Record, Manage and Monitor'.