

6 Balaclava Court, Penygraig, Tonypandy.				Survey Type >			Management		Initial Survey Date(s) >							26/03/2011						
2220AS410																Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Risk ratings				Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"						
G			NGA39 93-1	2220AS41 0-001	All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	36SM	NA	NA	NA	NA	NA	NA	No action not an ACM	26/03/11				
G			NGA39 93-2	2220AS41 0-002	Kitchen	Under side of sink and drainer	Bitumen pads	Bitumen coatings on metal	Negative asbestos sample	2No	NA	NA	NA	NA	NA	NA	No action not an ACM	26/03/11				
H				2220AS41 0-003	Kitchen	Floor	Beige vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	No action not an ACM	26/03/11				
H				2220AS41 0-004	Bathroom	Floor	Blue vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	26/03/11				
H				2220AS41 0-005	Bathroom	Boxing to wall	Boxing board	Insulating board	Discounted material (not sampled)	3LM	NA	NA	NA	NA	NA	NA	No action not an ACM	26/03/11			Superlux	