

| 10 Cern Y Celyn Close, Penygraig, Tonypanyd. | | | | Survey Type > | | | Management | | Initial Survey Date(s) > | | | | | | | 25/03/2011 | | | | | | |
|--|----------------------------|----------------------|------------|----------------|---------------------------------------|---------------------|----------------------------|---|-----------------------------------|--------------------------|------------------|-----------|----------------------|--------------------------------|--------------------------------|-------------------------|---|----------------|-------------------------|------------------------|------|----------------|
| 2220AS429 | | | | | | | | | | | | | | | | Management Action | | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Risk ratings | | |  | Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| | | | | | | | | | | | | | | Total Material Risk rating "A" | Total Priority Risk rating "B" | Total Risk Rating "A+B" | | | | | | |
| G | | | NGA40 15-1 | 2220AS42 9-001 | Kitchen | Under side of sink | Bitumen pad | Bitumen coatings on metal | Negative asbestos sample | 1No | NA | NA | NA | NA | NA | NA | No action not an ACM | 25/03/11 | | | | |
| G | | | NGA40 15-2 | 2220AS42 9-002 | Hall, bedroom 2, bathroom and kitchen | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 36SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 25/03/11 | | | | |
| G | | | NGA40 15-3 | 2220AS42 9-003 | Bedroom 1 and lounge | Ceilings | 'Artex' - 'Comb' | Textured coatings & joint compound | Negative asbestos sample | 24SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 25/03/11 | | | | |
| H | | | | 2220AS42 9-004 | Bathroom | Floors | Beige vinyl sheet flooring | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 18SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 25/03/11 | | | | |
| H | | | | 2220AS42 9-005 | Roof space | Under roof covering | Sarking felt | Bitumen roofing felts | Discounted material (not sampled) | 50SM | NA | NA | NA | NA | NA | NA | No action not an ACM | 25/03/11 | | | | |