125 Bute Street, Treherbert, Treorchy.						Survey Type >		Type 2									Initial Survey Date(s) >	05/01/2010			
2220AS43														Risk ratings			Management Action				
Report Section	Extrapolated from Site Ref	UPRN	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	Accessibility	Damage	Surface treatment	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G		04BUT12500	00005/B005-1	2220AS43-001	Ground floor - Lounge	Ceiling	'Artex' - 'Circle'	Textured coatings & joint compound	Negative asbestos sample	12SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/01/10			
G		04BUT12500	00005/B005-2	2220AS43-002	Ground floor - Stairway, kitchen, bathroom and hall. First floor - Bedrooms 1and 2	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	52SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/01/10			
G		04BUT12500	00005/B005-3	2220AS43-003	Ground floor - Kitchen and hall	Floor	Beige vinyl tiles	PVC vinyl floor tiles & unbacked PVC flooring	Negative asbestos sample	14SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/01/10			
G		04BUT12500	00005/B005-4	2220AS43-004	Ground floor - Kitchen	Underside sink top	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	No action not an ACM	05/01/10			
G		04BUT12500	00005/B005-5	2220AS43-005	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/01/10			