

241 Brithweunydd, Trealaw, Tonypanyd.					Survey Type >			Management		Initial Survey Date(s) >							11/01/2012						
2220AS545																	Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** A accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"			Last date ACM inspected	Last date ACM modified	Note	Licensed work?
																		Recommendation					
E				2220AS545-004	GF - Lounge	Under laminated flooring	N/A	No access (Presumption)	No access (Presumption)	21SM	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	01/09/23	20/12/16			
G			NGA5721-1	2220AS545-001	GF - Kitchen	Ceiling	'Artex' - 'Comb'	Textured coatings & joint compound	Negative asbestos sample	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
G			NGA5721-2	2220AS545-002	GF - Kitchen	Under side sink top	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
G			NGA5721-3	2220AS545-005	GF - Hall	Ceiling	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	3SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
G			NGA5721-4	2220AS545-006	GF - Under stair cupboard	Ceiling	'Artex' - 'Random'	Textured coatings & joint compound	Negative asbestos sample	2SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
G			NGA5721-5	2220AS545-007	FF - Bathroom and landing	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
G			NGA5721-6	2220AS545-008	FF - Bedrooms 1, 2 and 3	Ceilings	'Artex' - 'Comb'	Textured coatings & joint compound	Negative asbestos sample	30SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
G			NGA5721-7	2220AS545-010	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Negative asbestos sample	50SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
H				2220AS545-003	GF - Kitchen	Floor	Grey sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				
H				2220AS545-009	FF - Bathroom	Floor	Black vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	11/01/12				