

11 Carn-y-Coed Close, Penygraig, Tonypanyd.						Survey Type >		Type 2		Initial Survey Date(s) >						27/04/2010					
2220AS55						Position	Component description	Material	Asbestos ID	Extent / approx quantity	Accessibility	Damage	Surface treatment	Risk ratings			Management Action				
Report Section	Extrapolated from Site Ref	UPRN	Lab Ref	Site Ref	Area or room									Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	 Recommendation				Last date ACM inspected
G			00005/B554-1	2220AS55-001	GF - Kitchen	Underside sink top	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	No action not an ACM	27/04/10			
G		0	00005/B554-2	2220AS55-003	GF - Kitchen, bathroom, hall and bedroom 2	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	32SM	NA	NA	NA	NA	NA	NA	No action not an ACM	27/04/10			
G		0	00005/B554-3	2220AS55-004	GF - Lounge and bedroom 1	Ceilings	'Artex' - 'Comb'	Textured coatings & joint compound	Negative asbestos sample	30SM	NA	NA	NA	NA	NA	NA	No action not an ACM	27/04/10			
G		0	00005/B554-4	2220AS55-006	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Negative asbestos sample	80SM	NA	NA	NA	NA	NA	NA	No action not an ACM	27/04/10			
H		0		2220AS55-002	GF - Kitchen	Floor	Brown vinyl cushion flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	10SM	NA	NA	NA	NA	NA	NA	No action not an ACM	27/04/10			
H		0		2220AS55-005	GF - Bathroom	Floor	Blue check sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	5SM	NA	NA	NA	NA	NA	NA	No action not an ACM	27/04/10			