

Kitchen - 14 Ashfield Close, Cymmer Road, Porth.					Survey Type >		Refurbishment		Initial Survey Date(s) >							03/07/2017						
2220AS597A					Register Type >		Final		Risk ratings							Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			NGA60 57-3	2220AS59 7A-003	Ground floor - Kitchen	Ceiling	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	11SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/07/17		Previously sampled as negative, please refer to 2220AS597-005	
G			PHH24 21-1	2220AS59 7A-005	Ground floor - Kitchen	Underside of worktops	Paper linings	Paper inc lining to 'strawboard'	Negative asbestos sample	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/07/17			
H				2220AS59 7A-001	Ground floor - Kitchen	Underside of sink	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/07/17			
H				2220AS59 7A-002	Ground floor - Kitchen	Floor	Black wood effect vinyl flooring sheet	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	11SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/07/17			
H				2220AS59 7A-004	Ground floor - Kitchen	Walls above worktops	Ceramic tiles	Ceramic	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/07/17			
H				2220AS59 7A-006	Ground floor - Kitchen	Under current floorings	Cream vinyl flooring sheet	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	11SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	03/07/17			