103 High Street, Treorchy.						Survey Type >		Management										Initial Survey Date(s) >				21/06/2010
2220AS60						Register Type >		Final							Risk ratings			Management Action				
Report Section	Extrapolated from Site Ref	UPRN (If applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			00005/B682-1	2220AS60-002	LGF - Kitchen and utility	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	28SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10			
G			00005/B682-2	2220AS60-003	LGF - Kitchen	Underside sink top and drainer	Bitumen Pads	Bitumen coatings on metal	Negative asbestos sample	2No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10			
G			00005/B682-3	2220AS60-006	GF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	28SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10			
G			00005/B682-4	2220AS60-007	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	28SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10			
G			00005/B682-5	2220AS60-008	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Negative asbestos sample	50SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10			
G			PHH29559-1	2220AS60-009	LFG - Kitchen	Floor	Tiles and adhesive	PVC vinyl flooring and adhesive	Negative asbestos sample	16SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	30/08/22			
H				2220AS60-004	LGF - Kitchen	Floor	Dark grey sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	14SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10			
H				2220AS60-005	GF - Hall	Floor by front door	Grey self stick vinyl tiles	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	2SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10			
I				2220AS60-001	GF - Lounge	Within back boiler	N/A	NA (no access)	Removed	NA	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	21/06/10		Fire removed (back boiler) new valiant boiler installed in basement kitchen	