| 23 Oakwood Drive, Thomastown, Porth. | | | | | | Survey Type > | | Management | | | | | | | | | | Initial Survey Date(s) > | | | | 10/02/2012 | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 2220AS601 | | | | | | | | | | | | | | | Risk ratings | | | Management Action | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (If applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" | Total Risk Rating "A+B" | Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| G | | | NGA6051-1 | 2220AS601-003 | GF - All areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 40SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/02/12 | | | |
| G | | | NGA6051-2 | 2220AS601-005 | GF - Hall | Under existing carpet | Beige vinyl tile and adhesive | PVC vinyl floor tiles & unbacked PVC flooring | Negative asbestos sample | 8SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/02/12 | | | |
| G | | | NGA6051-3 | 2220AS601-006 | FF - All areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 40SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/02/12 | | | |
| H | | | | 2220AS601-001 | GF - Kitchen | Underside sink top | Bitumen pad | Bitumen coatings on metal | Discounted material (not sampled) | 1No | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/02/12 | | New kitchen | |
| H | | | | 2220AS601-002 | GF - Kitchen | Floor | Brown speck sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 15SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/02/12 | | | |
| H | | | | 2220AS601-004 | GF - Toilet. FF - Bathroom | Floors | Beige sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 6SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/02/12 | | | |
| H | | | | 2220AS601-007 | Roof space | Under roof covering | Sarking felt | Bitumen roofing felts | Discounted material (not sampled) | 50SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/02/12 | | | |