| 24 Fforch Close, Cemetery Road, Treorchy. | | | | | | Survey Type > | | Management | | | | | | | | | | Initial Survey Date(s) > | | | 18/06/2012 | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 2220AS615 | | | | | | | | | | | | | | | Risk ratings | | | Management Action | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (If applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" | Total Risk Rating "A+B" | Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| G | | | NGA6871-1 | 2220AS615-002 | GF - All areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 40SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| G | | | NGA6871-2 | 2220AS615-004 | FF - Landing, bathroom and bedroom 2 | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 24SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| G | | | NGA6871-3 | 2220AS615-005 | FF - Bedroom 1 | Ceiling | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 14SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| G | | | NGA6871-4 | 2220AS615-009 | External - Porch | Under cloak | Lining board | Insulating board | Negative asbestos sample | 2LM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| G | | | NGA6871-5 | 2220AS615-010 | GF - Kitchen | Rear of boiler | Lining board | Insulating board | Negative asbestos sample | 1SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| H | | | | 2220AS615-001 | GF - Kitchen | Under side sink top | Bitumen pad | Bitumen coatings on metal | Discounted material (not sampled) | 1No | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| H | | | | 2220AS615-003 | GF - Kitchen | Floor | Grey speck sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 12SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| H | | | | 2220AS615-006 | FF - Bathroom | Floor | Grey sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | Wet room | |
| H | | | | 2220AS615-007 | Roof space | Under roof covering | Sarking felt | Bitumen roofing felts | Discounted material (not sampled) | 50SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | | |
| H | | | | 2220AS615-008 | External - Walls | Lower brick work | Damp proof course | Bitumen damp proof courses | Discounted material (not sampled) | 12LM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 18/06/12 | | Plastic | |