

10 Fforch Close, Cemetery Road, Treorchy.				Survey Type >			Management		Initial Survey Date(s) >							18/06/2012						
2220AS616																Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	PHH ENVIRONMENTAL Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			NGA68 72-1	2220AS61 6-001	GF - Kitchen	Under side of sink	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
G			NGA68 72-2	2220AS61 6-002	GF - Hall, toilet and kitchen	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	22SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
G			NGA68 72-3	2220AS61 6-003	GF - Kitchen	Behind boiler on wall	lining board	Insulating board	Negative asbestos sample	1SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
G			NGA68 72-4	2220AS61 6-006	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
G			NGA68 72-5	2220AS61 6-009	External - Roof and porch	Undercloak top gable end and porch verges	lining board	Insulating board	Negative asbestos sample	12LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
H				2220AS61 6-004	GF - Hall	Floor	Brown vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	5SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
H				2220AS61 6-005	GF - Kitchen	Floor	Beige speckled vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	12SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
H				2220AS61 6-007	FF - Bathroom	Floor	Beige vinyl sheet flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
H				2220AS61 6-008	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12			
H				2220AS61 6-010	External	Low level brick work	D.P.C	Bitumen damp proof courses	Discounted material (not sampled)	18LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	18/06/12		Plastic	