

36 Ty Mawr Uchaf, Hafod Lane, Hopkinstown, Pontypridd.					Survey Type >			Management		Initial Survey Date(s) >							29/06/2012						
2220AS657																	Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"			Last date ACM inspected	Last date ACM modified	Note	Licensed work?
																		Recommendation					
A			NGA69 41-2	2220AS65 7-006	Gable and porch canopy	Undercloak	Lining board	Insulating board	Positive asbestos sample	12LM	0	0	2	1	5	1	6	Record, manage & monitor	20/11/23				Yes
G			NGA69 41-1	2220AS65 7-004	All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	29/06/12				
G			NGA69 41-3	2220AS65 7-007	Lounge	Pad on ironing board	Lining board	Insulating board	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	29/06/12				
H				2220AS65 7-001	Kitchen	Under side sink top	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	29/06/12				
H				2220AS65 7-002	Kitchen	Floor	Beige sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	29/06/12				
H				2220AS65 7-003	Bathroom	Floor	Beige vinyl tile	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	29/06/12				
H				2220AS65 7-005	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	29/06/12				

* risk assessment required prior to work.

Where 'Carry Out Repairs', 'Seal', 'Encapsulate' or 'Enclose' is recommended, it is implicit that the ACM is also classified as 'Record, Manage and Monitor'.