

11 Ty Mawr Uchaf, Hafod Lane, Hopkinstown, Pontypridd.					Survey Type >			Management		Initial Survey Date(s) >							09/07/2012						
2220AS668																	Management Action						
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	PHH ENVIRONMENTAL		Last date ACM inspected	Last date ACM modified	Note	Licensed work?
																		Recommendation					
A			NGA69 64-3	2220AS66 8-005	Gable end and porch	Under cloak	Lining board	Insulating board	Positive asbestos sample	12LM	0	0	2	1	5	1	6	Record, manage & monitor	20/11/23				Yes
G			NGA69 64-1	2220AS66 8-001	All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/12				
G			NGA69 64-2	2220AS66 8-002	Kitchen	Underside sink top	Bitumen pad	Bitumen coatings on metal	Negative asbestos sample	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/12				
H				2220AS66 8-003	Bathroom and kitchen	Floors	Beige vinyl tile	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	10SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/12				
H				2220AS66 8-004	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	09/07/12				