

Kitchen - 20 Graig Wen, Maerdy, Ferndale.				Survey Type >		Refurbishment		Initial Survey Date(s) >							24/09/2019								
2220AS707A				Register Type >		Final		Risk ratings							Management Action								
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B" - Score breakdown available on request	Total Risk Rating "A+B"	 Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?	
G			NGAR0 0223-2	2220AS70 7A-001	Kitchen	Ceiling	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	6SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/09/19			Previously sampled as negative, please refer to 2220AS707-5	
G			PHH13 079-1	2220AS70 7A-003	Kitchen	Around sink	Mastic	Bitumen mastic, caulking & putty	Negative asbestos sample	5LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/09/19				
H				2220AS70 7A-002	Kitchen	Floor	Sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	5SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/09/19			Wooden floor below.	