

4 Park Place, Maerdy, Ferndale.						Survey Type >		Unlicensed software		Initial Survey Date(s) >							05/11/2012				
2220AS794																	Management Action				
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	(1 Asbestos type = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Risk ratings			Last date ACM inspected	Last date ACM modified	Note	Licensed work?
E				2220AS79 4-001	GF - Kitchen	Under ceramic tiles	N/A	No access (Presumption)	No access (Presumption)	15SM	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	11/05/16			
E				2220AS79 4-003	GF - Hall and lounge	Under laminate	N/A	No access (Presumption)	No access (Presumption)	20SM	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	11/05/16			
G			NGAR 00600-1	2220AS79 4-004	GF - Kitchen and hall	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	16SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/11/12			
G			NGAR 00600-2	2220AS79 4-005	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	36SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/11/12			
H				2220AS79 4-002	GF - Kitchen	Under sink and drainer	Bitumen pads	Bitumen coatings on metal	Discounted material (not sampled)	2No	NA	NA	NA	NA	NA	NA	No action not an ACM	05/11/12			
H				2220AS79 4-006	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	45SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/11/12			
H				2220AS79 4-007	FF - Bathroom	Floor	Wood effect sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/11/12			
H				2220AS79 4-008	FF - Bathroom	Under vinyl	Beige sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	05/11/12			