

1 Stanley Court, Tallis Street, Cwmparc, Treorchy.					Survey Type >			Management		Initial Survey Date(s) >							25/06/2010					
2220AS81										Risk ratings							Management Action					
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	* Accessibility	* Damage	* Surface treatment	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"		Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
A		07ST A001 00	00005/B700-5	2220AS81-008	External	Undercloak	Lining board	Cement - Fully comp flat sheet, tiles, slates & boards	Positive asbestos sample	10LM	0	0	1	5	1	6	Record, manage & monitor	16/11/23				No*
G		07ST A001 00	00005/B700-1	2220AS81-001	GF - Kitchen	Underside sink top and drainer	Bitumen Pads	Bitumen coatings on metal	Negative asbestos sample	2No	NA	NA	NA	NA	NA	NA	No action not an ACM	25/06/10				
G		07ST A001 00	00005/B700-2	2220AS81-002	GF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	36SM	NA	NA	NA	NA	NA	NA	No action not an ACM	25/06/10				
G		07ST A001 00	00005/B700-3	2220AS81-003	GF - Kitchen, hall and understair cupboard	Floors	Beige vinyl tile and adhesive	PVC vinyl floor tiles & unbacked PVC flooring	Negative asbestos sample	14SM	NA	NA	NA	NA	NA	NA	No action not an ACM	25/06/10			Tiles under existing floor covering in hall	
G		07ST A001 00	00005/B700-4	2220AS81-005	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	36SM	NA	NA	NA	NA	NA	NA	No action not an ACM	25/06/10				
H		07ST A001 00		2220AS81-004	GF - Rear lobby	Floor	Grey sheet cushion flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	1SM	NA	NA	NA	NA	NA	NA	No action not an ACM	25/06/10				
H		07ST A001 00		2220AS81-006	FF - Bathroom	Floor	Grey sheet vinyl flooring	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	No action not an ACM	25/06/10				
H		07ST A001 00		2220AS81-007	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	45SM	NA	NA	NA	NA	NA	NA	No action not an ACM	25/06/10				