

| Bathroom and kitchen - 7 The Poplars, Willow Road, Llanharry, Pontyclun. | | | | | Survey Type > | | | Refurbishment | | Initial Survey Date(s) > | | | | | | | 19/07/2016 | | | | | |
|--|----------------------------|----------------------|-------------|----------------|------------------------|---|-------------------------|---|-----------------------------------|--------------------------|------------------|-----------|----------------------|--|--------------------------------|---|-------------------------|--|-------------------------|------------------------|---|----------------|
| 2220AS819A | | | | | Register Type > | | | Final | | Risk ratings | | | | | | | Management Action | | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (if applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" - Score breakdown available on request | Total Risk Rating "A+B" |  Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| G | | | NGAR01395-2 | 2220AS819A-004 | First floor - Bathroom | Ceiling | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | Previously sampled as negative, please refer to management report | |
| G | | | NGAR7967-1 | 2220AS819A-008 | First floor - Bathroom | Under two layers of flooring | Beige vinyl tiles | PVC vinyl floor tiles & unbacked PVC flooring | Negative asbestos sample | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | | |
| G | | | NGAR01395-1 | 2220AS819A-012 | Ground floor - Kitchen | Ceiling | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 15SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | Previously sampled as negative, please refer to management report | |
| G | | | NGAR7967-2 | 2220AS819A-013 | Ground floor - Kitchen | Under side of worktops | Paper lining | Paper inc lining to 'strawboard' | Negative asbestos sample | 3SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | | |
| H | | | | 2220AS819A-001 | First floor - Bathroom | Walls around bath | Ceramic tiles | Ceramic | Discounted material (not sampled) | 3SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | | |
| H | | | | 2220AS819A-002 | First floor - Bathroom | Vertical boxing | Lining board | Insulating board | Discounted material (not sampled) | 5LM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | Plywood | |
| H | | | | 2220AS819A-003 | First floor - Bathroom | Bath panel | Lining board | Insulating board | Discounted material (not sampled) | 1SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | Wooden tongue and groove panelling | |
| H | | | | 2220AS819A-005 | First floor - Bathroom | Floor | Black vinyl sheet | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | | |
| H | | | | 2220AS819A-006 | First floor - Bathroom | Walls within bathroom to bedroom and landing side | Lining board | Insulating board | Discounted material (not sampled) | 7SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | Plasterboard | |
| H | | | | 2220AS819A-007 | First floor - Bathroom | Under current flooring | Tile effect vinyl tiles | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | Self adhesive tiles | |
| H | | | | 2220AS819A-009 | Ground floor - Kitchen | Floor | Black vinyl tiles | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 6SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | Self adhesive tiles | |
| H | | | | 2220AS819A-010 | Ground floor - Kitchen | Within wall mounted boiler | Gaskets | Textiles - Gaskets & washers | Discounted material (not sampled) | Small Quants | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | New vaillant boiler | |
| H | | | | 2220AS819A-011 | Ground floor - Kitchen | Walls above worktops | Ceramic tiles | Ceramic | Discounted material (not sampled) | 2SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 19/07/16 | | | |