

37 Gelli Fedi Rise, Brynna, Pontyclun.				Survey Type >			Management		Initial Survey Date(s) >							20/06/2013								
2220AS913																Management Action								
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	(1 Asbestos type = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	 Recommendation			Last date ACM inspected	Last date ACM modified	Note	Licensed work?
G			NGAR 01572-1	2220AS91 3-004	GF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	35SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					
G			NGAR 01572-2	2220AS91 3-006	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	35SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					
H				2220AS91 3-001	GF - Kitchen	Under side sink top	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					
H				2220AS91 3-002	GF - Kitchen	Floor	Wood effect sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	15SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					
H				2220AS91 3-003	GF - Kitchen	Under current flooring	Grey sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	15SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					
H				2220AS91 3-005	FF - Bathroom	Floor	Blue sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					
H				2220AS91 3-007	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	45SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					
H				2220AS91 3-008	External	Low level brick work	D.P.C	Bitumen damp proof courses	Discounted material (not sampled)	30LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	20/06/13					