

Flat 8 Pendyrus Court, Tylorstown, Ferndale.				Survey Type >			Management		Initial Survey Date(s) >							08/07/2013								
2220AS933																Management Action								
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	(1 Asbestos type = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Risk ratings			PHH ENVIRONMENTAL			Last date ACM inspected	Last date ACM modified	Note	Licensed work?
														Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	Recommendation							
G			NGAR 01651-1	2220AS93 3-003	All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	33SM	NA	NA	NA	NA	NA	NA	No action not an ACM	08/07/13						
H				2220AS93 3-001	Kitchen	Under side sink top	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1SM	NA	NA	NA	NA	NA	NA	No action not an ACM	08/07/13						
H				2220AS93 3-002	Bathroom and kitchen	Floors	Grey sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	No action not an ACM	08/07/13						