

10 The Poplars, Willow Road, Llanharry, Pontyclun.				Survey Type >			Management		Initial Survey Date(s) >							24/07/2013							
2220AS956																Management Action							
Report Section	Extrapolated from Site Ref	UPRN (if applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	(1 Asbestos type = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	PHH ENVIRONMENTAL Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?	
G			NGAR 01719-1	2220AS956-003	GF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				
G			NGAR 01719-2	2220AS956-005	FF - All areas	Ceilings	'Artex' - 'Stipple'	Textured coatings & joint compound	Negative asbestos sample	40SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				
G			NGAR 01719-3	2220AS956-006	External - Porch	Under cloak	Lining board	Insulating board	Negative asbestos sample	2LM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				
H				2220AS956-001	GF - Kitchen	Under side sink top	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				
H				2220AS956-002	GF - Cupboard in kitchen and toilet FF - bathroom	Floors and under current floor in FF - bathroom	Beige sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				
H				2220AS956-004	FF - Bathroom	Floor	Grey sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	4SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				
H				2220AS956-007	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	50SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				
H				2220AS956-008	External	Low level brick work	Damp proof course	Bitumen damp proof courses	Discounted material (not sampled)	35SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	24/07/13				