Emergency Room and Communal Areas 21 Llwynypia Road, Tonypandy.						Survey Type >		Update Asbestos Survey							Initial Survey Date(s) >			25/07/2013			
2220AS962															Risk ratings			Management Action			
Report Section	Extrapolated from Site Ref	UPRN (If applicable)	Lab Ref	Site Ref	Area or room	Position	Component description	Material	Asbestos ID	Extent / approx quantity	** Accessibility	** Damage	** Surface treatment	Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite)	Total Material Risk rating "A"	Total Priority Risk rating "B"	Total Risk Rating "A+B"	Recommendation	Last date ACM inspected	Last date ACM modified	Note	Licensed work?
E				2220AS962-007	External	Soffits and under cloak	N/A	No access (Presumption)	No access (Presumption)	42LM	NA	NA	NA	NA	NA	NA	NA	Re-evaluate if access obtained	04/04/25		No access above plastic uPVC	
G			NGAR01728-1	2220AS962-003	GF - Emergency room and communal hallway	Ceilings	'Artex' - 'Random'	PVC vinyl floor tiles & unbacked PVC flooring	Negative asbestos sample	19SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	25/07/13			
H				2220AS962-001	GF - Emergency room	Under side sink top	Bitumen pad	Bitumen coatings on metal	Discounted material (not sampled)	1No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	25/07/13			
H				2220AS962-002	GF - Emergency room - All areas	Floors	Grey sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	13SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	25/07/13			
H				2220AS962-004	GF - Hall	Stair nosing	Black stair treads	Reinforced plastic and resin composites	Discounted material (not sampled)	19No	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	25/07/13			
H				2220AS962-005	GF - Hall and landing	Floor	Dark grey sheet vinyl	PVC vinyl floor tiles & unbacked PVC flooring	Discounted material (not sampled)	6SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	25/07/13			
H				2220AS962-006	Roof space	Under roof covering	Sarking felt	Bitumen roofing felts	Discounted material (not sampled)	65SM	NA	NA	NA	NA	NA	NA	NA	No action not an ACM	25/07/13			