| 22 Llys Catwg, New Park, Talbot Green, Pontyclun. | | | | | | Survey Type > | | Management | | | | | | | | | | | Initial Survey Date(s) > | 02/08/2013 | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 2220AS977 | | | | | | | | | | | | | | | Risk ratings | | | | Management Action | | | | |
| Report Section | Extrapolated from Site Ref | UPRN (If applicable) | Lab Ref | Site Ref | Area or room | Position | Component description | Material | Asbestos ID | Extent / approx quantity | ** Accessibility | ** Damage | ** Surface treatment | Asbestos type (1 = Chrysotile, 2 = Amosite, 3 = Crocidolite) | Total Material Risk rating "A" | Total Priority Risk rating "B" | Total Risk Rating "A+B" | Recommendation | Last date ACM inspected | Last date ACM modified | Note | Licensed work? |
| G | | | NGAR 01780-1 | 2220AS977-004 | GF - Under stairs cupboard, hall and lounge | Floor in under stairs cupboard and under laminate in hall and lounge | Grey vinyl tile and adhesive | PVC vinyl floor tiles & unbacked PVC flooring | Negative asbestos sample | 23SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| G | | | NGAR 01780-2 | 2220AS977-005 | GF - Lounge | Ceiling | 'Artex' - 'Finger' | Textured coatings & joint compound | Negative asbestos sample | 15SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| G | | | NGAR 01780-3 | 2220AS977-006 | GF - All areas except lounge | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 28SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| G | | | NGAR 01780-4 | 2220AS977-008 | FF - All areas | Ceilings | 'Artex' - 'Stipple' | Textured coatings & joint compound | Negative asbestos sample | 40SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| G | | | NGAR 01780-5 | 2220AS977-010 | Main roof and porch | Under cloak | Lining board | Insulating board | Negative asbestos sample | 16LM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| H | | | | 2220AS977-002 | GF - Kitchen | Floor | Wood effect sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 15SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | Screed underneath | |
| H | | | | 2220AS977-003 | GF - Toilet | Floor | Grey sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 2SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| H | | | | 2220AS977-007 | FF - Bathroom | Floor | Black sheet vinyl | PVC vinyl floor tiles & unbacked PVC flooring | Discounted material (not sampled) | 4SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| H | | | | 2220AS977-009 | Roof space | Under roof covering | Sarking felt | Bitumen roofing felts | Discounted material (not sampled) | 50SM | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 02/08/13 | | | |
| I | | | | 2220AS977-001 | GF - Kitchen | Within wall mounted boiler | N/A | No access (Presumption) | Removed | Small Quants | NA | NA | NA | NA | NA | NA | NA | No action not an ACM | 10/10/18 | | New vaillant boiler installed | |