

# KOVIA<sup>®</sup>

## Asbestos Consultancy

+44(0)1752 875 642

kovia.co.uk

info@kovia.co.uk

## Sampling Survey

Flat 7  
St. Peters Court  
Pentre Road  
Pentre  
Mid Glamorgan  
CF417DQ  
UPRN: 006404



Kovia Ltd  
1 Davy Road  
Derriford  
Plymouth  
PL6 8BX





**Plan Key:**



Positive or Strongly Presumed Asbestos in area / room



No Access within or to area / room

Client: Wales & West Housing  
Site: Flat 7 Building: Flat 7, Block 1-7  
Floor: Ground Floor  
UPRN No: 006404





**ENVIROCHEM**  
**Analytical Laboratories Ltd.**  
12 The Gardens  
Broadcut, Fareham  
Hampshire  
PO16 8SS



1227

Tel: (01329) 287777

Fax: (01329) 287755

www.envirochem.co.uk

office@envirochem.co.uk

Our Ref: J185192 FI: 1

Your Ref:

Date: 18/02/2020

## Asbestos Fibre Identification Report

**Client:** Kovia Asbestos Management Consultancy  
1 Davy Road, Derriford, Plymouth, PL6 8BX

**Site Address:** Flat 7, St. Peters Court, Pentre Road, Pentre, Mid Glamorgan, CF417DQ

**Sampled By:** Kovia Asbestos Management Consultancy

**Date sampled/received:** 18th February 2020

**Date analysed:** 18th February 2020

**Analyst/s:** Bradley Travis

**Analysis Location:** 12 The Gardens, Broadcut, Fareham, Hampshire, PO16 8SS

### ANALYTICAL PROCEDURE

Fibre identification was carried out in accordance with the documented 'in-house' method (2.01) based on the HSE Guidance Note HSG 248. These employed stereo microscopy, polarized microscopy and dispersion staining techniques.

### RESULTS

Sample No.	Sample Ref.	Location	Asbestos Detected	Asbestos Type
AI008696	BS602748	Ground Floor, Shower Room, Textured coating	No	

#### NOTES:

1. Sample(s) were examined for the presence of 6 types of asbestos fibres: crocidolite (blue), amosite (brown), chrysotile (white), anthophyllite, actinolite and tremolite.
2. The results shown in this test report specifically refer to the sample(s) tested as received unless otherwise stated and samples collected by the client are evaluated using information provided by the client. For samples collected by the client the date of receipt is deemed to be the same as the date sampled.
3. Envirochem is a UKAS accredited laboratory for sampling and identification of asbestos containing materials.
4. Comments, observations and opinions are outside the scope of UKAS accreditation.
5. The analytical method in the HSG248 does not quantify the amount of asbestos present, therefore UKAS accreditation does not permit quantification.
6. If, during fibre identification, only 1 or 2 fibres are seen and identified as asbestos, then the term 'trace asbestos identified' is used.
7. This report shall not be reproduced except in full, without written approval of Envirochem.

SIGNATURE:

Authorised signatory

PRINT NAME: Bradley Travis

**Reg. No. 2378228 England. Registered Office: Envirochem, 12 The Gardens, Broadcut, Fareham, Hampshire, PO16 8SS.**