

KOVIA[®]

Asbestos Consultancy

+44(0)1752 875 642

kovia.co.uk

info@kovia.co.uk

Sampling Survey

33 Trem Y
Mynydd
Treherbert
Treorchy
Mid
Glamorgan
CF42 5LJ
UPRN:
006700



Kovia Ltd
1 Davy Road
Derriford
Plymouth
PL6 8BX




Plan Key:



Positive or Strongly Presumed Asbestos in area / room



No Access within or to area / room



Client: Wales & West Housing
Site: 33 Trem Y Mynydd Building: Main flat
Floor: External
UPRN No: 006700





ENVIROCHEM
Analytical Laboratories Ltd.
12 The Gardens
Broadcut, Fareham
Hampshire
PO16 8SS



1227

Our Ref: J146553 FI: 1
Your Ref:
Date: 13/06/2018

Tel: (01329) 287777
Fax: (01329) 287755
www.envirochem.co.uk
office@envirochem.co.uk

Asbestos Fibre Identification Report

Client: Kovia Asbestos Management Consultancy
1 Davy Road, Derriford, Plymouth, PL6 8BX

Site Address: 33 Trem Y Mynydd, Treherbert, Treorchy, Mid Glamorgan, CF42 5LJ

Sampled By: Kovia Asbestos Management Consultancy

Date sampled/received: 12th June 2018

Date analysed: 13th June 2018

Analyst/s: Matt Hurst

Analysis Location: 12 The Gardens, Broadcut, Fareham, Hampshire, PO16 8SS

ANALYTICAL PROCEDURE

Fibre identification was carried out in accordance with the documented 'in-house' methods based on the HSE Guidance Note HSG 248. These employed stereo microscopy, polarized microscopy and dispersion staining techniques.

RESULTS

Sample No.	Sample Ref.	Location	Asbestos Detected	Asbestos Type
AI004021	BS492456	External, External - Roof Area, Undercloak	Yes	Chrysotile

NOTES:

1. Sample(s) were examined for the presence of 6 types of asbestos fibres: crocidolite (blue), amosite (brown), chrysotile (white), anthophyllite, actinolite and tremolite.
2. Samples collected by the client are evaluated using information provided by the client. For samples collected by the client the date of receipt is deemed to be the same as the date sampled.
3. Envirochem is a UKAS accredited laboratory for sampling and identification of asbestos containing materials.
4. Comments, observations and opinions are outside the scope of UKAS accreditation.
5. The analytical method in the HSG248 does not quantify the amount of asbestos present, therefore UKAS accreditation does not permit quantification.
6. If, during fibre identification, only 1 or 2 fibres are seen and identified as asbestos, then the term 'trace asbestos identified' is used.

SIGNATURE:

Authorised signatory

PRINT NAME: Frances Scott

Reg. No. 2378228 England. Registered Office: Envirochem, 12 The Gardens, Broadcut, Fareham, Hampshire, PO16 8SS.